



Government of Tripura
Directorate of Fire & Emergency Services
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: dfireservicetripura@gmail.com. Website: www.fireservice.tripura.gov.in

No.3-8/TFES/2022/ 8018-21

Dated, Agartala, the 19th Sept., 2022.

To
The Principal,
Derozeo Mission School,
Jambura, Khowai, Tripura.
E-mail: dmskhowai@gmail.com, Mob. No. 9862149007.

Subject: - Issuance of Temporary/Provisional Fire NOC.

Sir,

With reference to your letter dated 10/08/2022, it is hereby certified that the building/premises as per description below has been inspected by the officer concerned of this department on 22.08.2022 and found that Fire Prevention and Fire Safety arrangements in the building/premises of this school are insufficient. However, 03 (three) months Temporary NOC is being issued subject to fulfillment of the Fire & Life Safety measures as per Advisory (copy enclosed). This provision of Fire NOC shall be treated as cancelled ab initio in case the school authority fails to take Fire & Life Safety measures as per Fire & Life Safety recommendations of Directorate, Home (Fire & Emergency Services), Tripura, Agartala.

Name & address of the proposed building/premises :- "Derozeo Mission School", Jambura, Khowai, Tripura.

Issued on 17-9-22 at Agartala.

N.B. Department is switching over offline issuance of NOC to online shortly. Therefore provisional / Temporary NOC is issued for a period of 03 (three) months. Thereafter, application to be submitted online (edistrict.tripura.gov.in) for Fire NOC.

Encl: As stated.

Yours faithfully,

Joint Director,

Tripura Fire & Emergency Services.

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance, exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

Copy to:

1. The Divisional Fire Officer, West Division, Agartala, Tripura for information and necessary action.
2. The OC, Agartala F&ES Station for information and necessary action.
3. The OC, Khowai F&ES Station for information and necessary action.